

ARABIAN ACRES METROPOLITAN DISTRICT

MONTHLY OPERATIONS REPORT

May 10, 2018 to June13, 2018

Submitted by: Lynn Willow, O.R.C/Operator

TOTAL WELL PRODUCTION

Control Building –A: 425,475 gallons

Control Building – B: 151,170 gallons

TOTAL PURCHASED WATER

Trucked – 0

(amount actually received per each 4,000 gallon load is generally 200-300 gallons less due to standard and typical hauling losses)

OPERATIONS & MAINTENANCE ISSUES

- 1) Bac-T samples for the month have been taken and are negative.
- 2) Prairie Dog population is getting smaller. We need to treat at least one more time this year.
- 3) Drought is having effect on well's. They are pumping longer to keep up.
- 4) Need to put drain pump into well # 2 meter pit to keep water out of pit. Estimated coast \$2,000.00
- 5) Customers need to contact me directly through phone call or email (both are on AAMD web site) if they have a concerns about water issues.

OTHER BUSINESS:

What is the status of AAMD credit card for petty cash?